

Fig. 1b

Fig. 1a




Fig. 2a




Fig. 2b




Fig. 3




Fig. 4




Fig. 5





Fig. 6

701



Oil Temperature (F) (+ / - 2%)	Component Operation
Ambient - 170	By-pass valve normally OPEN, 90% oilflow by-pass to reservoir
170 - 180	By-pass valve begins to CLOSE
180+	By-pass valve fully CLOSED, 100% oilflow to oil cooler
210+	Thermostat switch CLOSED, oil cooler fan ON
190	Thermostat switch OPEN, oil cooler fan OFF

Fig. 7